

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES**

Memo No : IND/WB/FES/20192020/83381

DATE: 24/02/2020

From :
The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.

To :
S K S PUBLIC SCHOOL
S K S PUBLIC SCHOOL
RONAI ROAD MANGALPUR RANIGANJ,PS.RANIGANJ,DIST.PASCHIM
BURDWAN.713347
Raniganj F.S., Raniganj PS,
Paschim Bardhaman - 713347 .

**Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction
of B + G + 2 storied building under group Educational at the premises no.- S K S
PUBLIC SCHOOL**
RONAI ROAD MANGALPUR RANIGANJ,PS.RANIGANJ,DIST.PASCHIM
BURDWAN.713347, Raniganj PS, Paschim Bardhaman - 713347

This is in reference to your Application No. IND/WB/FES/20192020/83381,dated 24/02/2020, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of B + G + 2 storied building under group Educational at the premises no.- S K S PUBLIC SCHOOL
RONAI ROAD MANGALPUR RANIGANJ,PS.RANIGANJ,DIST.PASCHIM
BURDWAN.713347, Raniganj PS, Paschim Bardhaman - 713347.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. However to up-keep the Fire Safety Measures of the G+I storied building, the following safety measures need to be incorporated.—
 1. Driveway must be free of any obstruction for easy movement of Fire Appliances. No Parking will be allowed in the Drive Way.
 2. The Interior finish decoration of building shall be made with low flame spread material conforming to the I.S. Specification.
 3. To eliminate of fire hazard, Good Housekeeping both inside and outside of the building shall be strictly maintained.
 4. Existing electrical wiring of the entire building shall have to be carefully checked for any wear and tear in them, particularly line above false ceiling & ducts.
 5. The Exit Sign and fire notice shall be maintained from fading and dust sedimentation and prepared and displayed at all venerable place.
 6. The employees and Security staffs shall be conversant with installed Fire Fighting Equipments of the building and operate in the event of fire and testing.
 7. Mock Fire Practice and Evacuation Drill shall be performed periodically with participation of all the occupant of the building.
 8. Special training to employees and staffs shall be give for carrying the ambulant(s) to the saferplace in the event of any exigency.
 9. Meter and Main room shall be removed to outside of the building and be protected with CO2 or D.C.P. Modular Fire Extinguishers.
 10. A Crew of trained fireman under an experienced officer shall be maintained round the clock for safety of the building and its occupants
 11. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good condition at all the time.
 12. If required the old electrical lines shall have to be replaced with new ones in M. S. conduit laying continuously bonded to the earth.
 13. Periodical flashing of water from the Landing valve and First Aid Fire Fighting Equipment shall be made to maintain the efficiency working performance of the Fire Fighting System Installed.
 14. The Fire Safety Audit to be conducted at a regular interval and to be recorded in the Fire Prevention Maintenance Register.

The Fire Safety Certificate is valid for THREE years and has to be renewed with in due date.

**Divisional Fire Officer
West Bengal Fire & Emergency Services**

Validity unknown
Digitally signed by NITAI
CHATTOPADHYAY
Date: 2020.02.24 16:04:55 IST